

# ADDENDUM NUMBER TWO

## SANTEE SCHOOL DISTRICT

**BID #2024-075-001, ELECTRIC VEHICLE SUPPLY EQUIPMENT (EVSE) INFRASTRUCTURE PROJECT SANTEE SCHOOL DISTRICT TRANSPORTION YARD**

**DATE: January 30, 2024**

General - All project documents including contract documents, drawings, and specifications, shall remain unchanged with the exception of those elements added, revised, deleted, or clarified by this addendum.

***Acknowledge receipt of Addendum Number Two in the appropriate place provided on the Bid Form***

Item No. 1 Addendum Two	Can you specify details for the hand-rated pull box?
A) Minimum pull box sizing is as required by CEC. For pull box requirements, please refer to Specification Section 26000 General Electric.	

Item No. 2 Addendum Two	What is feeding the charge management system (CMS) box?
A) Each charging station requires a dedicated, hard-wired CAT6 connection to the CMS box. CMS box will be provided by the District through selected CMS provider (InCharge). Please refer to the Design Drawings, Specifications, and CMS provider’s installation manual for more detail.	

Item No. 3 Addendum Two	Can you specify the K-Rail details for communication conduits?
A) Please refer to the Design Drawings and Specifications. Additional guidance on communication conduits that is not explicitly included in the Design Drawings and Specification would likely fall under construction means and methods for the selected vendor and may be discussed with the District after bid opening.	

Item No. 4 Addendum Two	For value engineering purposes, can the switchgear be relocated next to the existing SDG&E pole in the parking lot?
A) The switchgear location was determined in coordination with SDG&E. Please provide a bid submission that conforms with the approved Design Drawings.	

Item No. 5 Addendum Two	For value engineering purposes and due to minimal access to pathways from the proposed location of the switchgear, would it be possible to add two (2) 600A panel boards in the parking lot closer to the EV charging stations?
A) Please provide a bid submission that conforms with the approved Design Drawings. The District may consider value engineering proposals from the selected vendor after bid opening.	

## END OF ADDENDUM NO. 2

### ADDENDUM NUMBER TWO

SANTEE SCHOOL DISTRICT BID #2024-075-001, ELECTRIC VEHICLE SUPPLY EQUIPMENT (EVSE)  
INFRASTRUCTURE PROJECT SANTEE SCHOOL DISTRICT TRANSPORTION YARD